

WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No. _____

(1) OWNER: Name Dick Glessner Address Hy. 525 Payview
 (2) LOCATION OF WELL: County Island - N 1/4, N 1/4, Sec 17 T. 89 N., R. 3 W. M.
 Bearing and distance from section or subdivision corner 660' W and 1220' S of NE Corn Sec 17

(3) **PROPOSED USE:** Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____

New well <input checked="" type="checkbox"/>	Method: Dug <input type="checkbox"/>	Bored <input type="checkbox"/>
Deepened <input type="checkbox"/>	Cable <input type="checkbox"/>	Driven <input type="checkbox"/>
Reconditioned <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>	Jetted <input type="checkbox"/>

(5) **DIMENSIONS:** Diameter of well 6 inches.
 Drilled 73 ft. Depth of completed well 73 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from ft. to ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used.....

SIZE of perforations in. by in.

..... perforations from ft. to ft.

..... perforations from ft. to ft.

..... perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK

Type _____ **Model No.** _____

Diam. 6" **Slot size** _____ **from** _____ **ft. to** _____ **ft.**

Diam. _____ **Slot size** _____ **from** _____ **ft. to** _____ **ft.**

Gravel packed: Yes ☐ No ☒ Size of gravel: ft.
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? _____ Depth of strata _____
Method of sealing strata off

(7) PUMP: Manufacturer's Name..... HP.....
Type:

(8) **WATER LEVELS:** Land-surface elevation above mean sea level. 300 ft.
 Static level 42' ft. below top of well Date
 Artesian pressure lbs. per square inch Date
 Artesian water is controlled by (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller

Yield: 18 gal./min. with max ft. drawdown after 1 hrs

" " " "

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)					
Time	Water Level	Time	Water Level	Time	Water Level
.....
.....
.....
.....
.....

Date of test
 Bailer test gal./min. with ft. drawdown after hr.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started..... 19..... Completed..... 19.....

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & W Drilling Co.
(Person, firm, or corporation) (Type or print)

Address P.O. Box 55 Freeport

[Signed] James Miller & Fisher
(Well Driller)

License No. 343 Date 10/10, 19 79